



Environmental Service Inc.

Oakridge Water System – Hydrant Flushing Plan ***Revised March 2021***

The Oakridge Water system as it is currently developed is equipped with 21 hydrants, upgraded from 17 in previous years, *as well as 35 newly installed water closet flushing valves (1 per water closet) to be flushed quarterly*. These are utilized for system flushing as part of a regular maintenance schedule, but also utilized for frequent water exchange to inhibit the excess development of Disinfection Byproducts (DBPs). **Quarterly flushing to be performed April, June, August, October as to avoid ice.**

HYDRANT LIST

Hydrant 1	Main Treatment Plant	Quarterly
Hydrant 2	Oakridge Drive	Quarterly
Hydrant 3	Deer Hill	Quarterly
Hydrant 4	Deer Hill 2 (New)	Quarterly
Hydrant 5	Maplewood	Quarterly
Hydrant 6	Boulder Ridge 1	Quarterly
Hydrant 7	Boulder Ridge 2	Quarterly
Hydrant 8	Boulder Ridge 3	Quarterly
Hydrant 9	Boulder Ridge 4	Quarterly
Hydrant 9	Lakeside 1	Quarterly
Hydrant 9	Lakeside 2	Quarterly
Hydrant 10	Laurel Ridge	Quarterly
Hydrant 11	Stonemeadow	Quarterly
Hydrant 12	Bittersweet	Quarterly
Hydrant 13	Bittersweet 2 (New)	Quarterly
Hydrant 14	Fox Run	Quarterly
Hydrant 15	Fox Run 2 (New)	Quarterly
Hydrant 16	Building 1	Quarterly
Hydrant 17	The Heights	Quarterly
Hydrant 18	Dentist	Quarterly
Hydrant 19	3 Split Rock	Bi- Weekly
Hydrant 20	32 Split Rock	Bi- Weekly
Hydrant 2	35 Split Rock	Bi- Weekly

