

George Latimer
County Executive

Sherlita Amler, M.D.
Commissioner of Health

April 6, 2022

Town of Lewisboro
11 Main St
South Salem, NY 10590
Attn: Mr. Tony Gonçalves, Town Supervisor

RE: Violation ID: 2022 1155;
2022 1156;
2022 1157;
2022 1158
Maximum Contaminant Level Violation
Oakridge Water District
Lewisboro (T)
Community Public Water Supply
PWS ID: NY 5918395

Dear Supervisor Gonçalves:

A review of Perfluorooctanesulfonic acid (PFOS), Perfluorooctanoic acid (PFOA), and 1,4-Dioxane sampling results for the 4th quarter 2021 monitoring period for the above referenced public water supply revealed that the PFOA level exceeded the Maximum Contaminant Level (MCL) of 0.0000100 milligrams per liter (mg/L) with an average value for the quarter of 0.0000112 mg/L at Well #5, 0.0000109 mg/L at Well #6, and 0.0000107 mg/L at Well #7. The above referenced public water supply has also exceeded the PFOS MCL of 0.0000100 mg/L with an average value for the quarter of 0.0000140 mg/L at Well #6. This constitutes non-compliance with Part 5, Subpart 5-1, Section 5-1.52, Table 3 of the New York State Sanitary Code (NYSSC).

You are reminded that Tier 2 Public Notification must be made within thirty (30) days from the date of this notice in accordance with Part 5, Subpart 5-1, Section 5-1.52 Table 13 and 5-1.78 of the NYSSC. Further, certification that the above notification was made and a copy of such notifications must be provided to the Department within ten (10) days of the completion of the notification requirement. A draft of the notice must be submitted to this Department for review prior to distribution.

Please be advised that the proposal for the installation of PFAS treatment system at Oakridge water treatment plant is under review by the Department. Once plan review is completed and Approval of Plans for the treatment system is issued, you will be notified immediately.

Please find the attached Notice of Violation forms generated by the New York State Department of Health Safe Drinking Water Information System (SDWIS) and recorded on its database.



Should you have any questions or require additional information, please contact Chika Amasiani at (914) 864-7338 or the undersigned at (914) 864-7348.

Very truly yours,

A handwritten signature in black ink, appearing to read 'Z.T.', followed by a horizontal line.

Zaw T. Thein, P.E.
Associate Engineer
Bureau of Environmental Quality

ZT:CA

Encl.

cc: Joel Smith, Facilities Manager, Town of Lewisboro
Tyler Post, Water System Operator, VRI
Phil Derrenbacher, Water System Operator, VRI
Andy Tse, NYSDOH
File

April 5, 2022
NOTICE OF VIOLATION
New York State Sanitary Code, 10 NYCRR Part 5

Mr. TONY GONCALVES
TOWN OF LEWISBORO
11 MAIN STREET
SOUTH SALEM, NY 10590

Re: 02 - MCL, AVERAGE
Violation ID: 2022 1156
Determination Date: April 5, 2022
OAKRIDGE WATER DISTRICT
PWS ID: NY5918395
Lewisboro, WESTCHESTER County

Dear Mr. TONY GONCALVES;

THIS IS A BASIC VIOLATION REPORT.

Violation ID: 2022 1156
Determination Date: 4/5/2022
Violation Type:
Name: 02 - MCL, AVERAGE
Analyte Group: PERFLUOROCTANOIC ACID (PFOA) - 2806
Analyte Name: PERFLUOROCTANOIC ACID (PFOA)
Analyte Code: 2806
Compliance Period Begin: 10/1/2021
Compliance Period End: 12/31/2021
Violation Period Begin Date: 10/1/2021
Violation Period End Date: 12/31/2021

April 5, 2022
NOTICE OF VIOLATION
New York State Sanitary Code, 10 NYCRR Part 5

Mr. TONY GONCALVES
TOWN OF LEWISBORO
11 MAIN STREET
SOUTH SALEM, NY 10590

Re: 02 - MCL, AVERAGE
Violation ID: 2022 1157
Determination Date: April 5, 2022
OAKRIDGE WATER DISTRICT
PWS ID: NY5918395
Lewisboro, WESTCHESTER County

Dear Mr. TONY GONCALVES;

THIS IS A BASIC VIOLATION REPORT.

Violation ID: 2022 1157
Determination Date: 4/5/2022
Violation Type:
Name: 02 - MCL, AVERAGE
Analyte Group: PERFLUOROCTANE SULFONIC ACID (PFOS) - 2805
Analyte Name: PERFLUOROCTANE SULFONIC ACID (PFOS)
Analyte Code: 2805
Compliance Period Begin: 10/1/2021
Compliance Period End: 12/31/2021
Violation Period Begin Date: 10/1/2021
Violation Period End Date: 12/31/2021

April 5, 2022
NOTICE OF VIOLATION
New York State Sanitary Code, 10 NYCRR Part 5

Mr. TONY GONCALVES
TOWN OF LEWISBORO
11 MAIN STREET
SOUTH SALEM, NY 10590

Re: 02 - MCL, AVERAGE
Violation ID: 2022 1158
Determination Date: April 5, 2022
OAKRIDGE WATER DISTRICT
PWS ID: NY5918395
Lewisboro, WESTCHESTER County

Dear Mr. TONY GONCALVES;

THIS IS A BASIC VIOLATION REPORT.

Violation ID: 2022 1158
Determination Date: 4/5/2022
Violation Type:
Name: 02 - MCL, AVERAGE
Analyte Group: PERFLUOROCTANOIC ACID (PFOA) - 2806
Analyte Name: PERFLUOROCTANOIC ACID (PFOA)
Analyte Code: 2806
Compliance Period Begin: 10/1/2021
Compliance Period End: 12/31/2021
Violation Period Begin Date: 10/1/2021
Violation Period End Date: 12/31/2021

April 5, 2022
NOTICE OF VIOLATION
New York State Sanitary Code, 10 NYCRR Part 5

Mr. TONY GONCALVES
TOWN OF LEWISBORO
11 MAIN STREET
SOUTH SALEM, NY 10590

Re: 02 - MCL, AVERAGE
Violation ID: 2022 1155
Determination Date: April 5, 2022
OAKRIDGE WATER DISTRICT
PWS ID: NY5918395
Lewisboro, WESTCHESTER County

Dear Mr. TONY GONCALVES;

THIS IS A BASIC VIOLATION REPORT.

Violation ID: 2022 1155
Determination Date: 4/5/2022
Violation Type:
Name: 02 - MCL, AVERAGE
Analyte Group: PERFLUOROCTANOIC ACID (PFOA) - 2806
Analyte Name: PERFLUOROCTANOIC ACID (PFOA)
Analyte Code: 2806
Compliance Period Begin: 10/1/2021
Compliance Period End: 12/31/2021
Violation Period Begin Date: 10/1/2021
Violation Period End Date: 12/31/2021