

TO: The Town of Lewisboro Planning Board
FROM: Lewisboro Conservation Advisory Council
SUBJECT: Wilson Residence
DATE: February 6, 2024

The Conservation Advisory Council (CAC) has reviewed the materials submitted by the applicant for addition and rain garden.

The additions have a total area of 861 ft within the wetland buffer. The applicant needs to provide a stormwater management plan (the rain garden being part of that) and a mitigation plan that meets the one-to-one criteria..